

**TESTMARK Laboratories Ltd.**

Committed to Quality and Service

CERTIFICATE OF ANALYSIS

Client: Claude Rancourt
Company: OCWA - SRF - Fauquier WTP
Address: 70 First Ave, Box 160
Smooth Rock Falls, ON, P0L 2B0
Phone: (705) 362-8481
Email: crancourt@ocwa.com
Sampled By: Rene Miville

Work Order Number: 399836
PO #: 18164
Regulation: O.Reg. 170
Project #: Org. # 5312
Fax: (705) 362-4684
DWS #: 210000979

Date Order Received: 5/12/2020
Arrival Temperature: 10 °C

Analysis Started: 5/12/2020
Analysis Completed: 5/13/2020

TEST RESULTS

Sample Description	Lab ID	Type / Matrix	Date / Time Collected	Field Chlorine		EC	TC	HPC
				Free	Combined			
F-1 Raw Water (Groundhog River) *	1535782	Raw / Raw Water	5/11/2020 10:40 AM			<5*	75*	
F-2 Treated Water	1535783	Entry / Treated Water	5/11/2020 10:45 AM		1.84	0	0	70
F-3 Town Hall	1535784	Distribution / Treated Water	5/11/2020 11:15 AM		1.63	0	0	
F-4 Bleeder	1535785	Distribution / Treated Water	5/11/2020 11:45 AM		1.13	0	0	70
F-4 Bleeder	1535785r	Distribution / Treated Water	5/11/2020 11:45 AM		1.13			40

Result Units: CFU/100mL (water matrix) CFU/g (soil matrix), except HPC which is CFU/1mL. Temp. is in Degrees Celsius.

Note that all tests have been performed in accordance with our accredited and licensed test methods (Method Reference A10 for E. coli, fecal, total coliform and background, and Method Reference A68 for HPC).

* Sample required dilution, please refer to the accompanying spreadsheet for sample-specific method detection limits.

REPORT COMMENTS

Bacti Lot # 1843

This report has been approved by:

Adam Tam, M.Sc.
Laboratory Director

LEGEND

TESTS EC - Escherichia coli, TC - Total Coliforms, FC - Fecal Coliforms, Back - Background, HPC - Heterotrophic Plate Count

RESULTS ~ - No Data. Results Pending.
INT - Interferences are evident on plate and therefore bacterial colonies cannot be properly counted (interferences can be anything that inhibit the proper growth and formation of target colonies)
NDOGN - No Data, Overgrown with Non-Target
NDOGT - No Data, Overgrown with Target
NDOGHPC - No Data. Overgrown with HPC
An 'r' after the Lab ID indicates a laboratory replicate.
Results relate only to the items tested.